K8	K8 K8 K8 K8 K8
	15 1 7
	Code No: 5421AA
	JAWAHARLAL NEHRU TECHNOLOGICAL UNIVERSITY HYDERABAD
	M.Tech I Semester Examinations, January - 2018
1/0	ADVANCED THERMODYNAMICS / C
KA.	(Thermal Engineering)
	Time: 3hrs Max.Marks:75
	Note: This question paper contains two parts A and B.
	Part A is compulsory which carries 25 marks. Answer all questions in Part A. Part B
	consists of 5 Units. Answer any one full question from each unit. Each question carries
	10 marks and may have a, b, c as sub questions.
K8	KS KS PART - A KS KS Marks = 25
	What is second law efficiency and its application in thermodynamics? [5]
	What is Joule's Thomson coefficient? Why is it zero for an ideal gas? [5]
	State the Gibbs phase rule. [5]
- don't	Draw the p-v and T-s diagrams for refrigeration cycle. [5]
1.00	e) How thermoelectric energy is generated? [5]
1/9	ZKQ KQ KQ KQ KX KX
(1,0)	YO YO YART-BYO NO IVO
	$5 \times 10 \text{ Marks} = 50$
	2. Air flows through an adiabatic compressor at 3 kg/s the inlet conditions are 2 bar and
	310k and exit conditions are 20 bar and 560 k. compute the net rate of availability
	transfer and irreversibility. [10]
	OR OR
K K	3.a) Establish the inequality of Clausitis. b) Two kg of air at 500 kPa, 80°C expands adiabatically in a closed system until its volume
$(\setminus \cup)$	is doubled and its temperature becomes equal to that of surroundings which is at 100 kPa,
-	5°C. For this process determine i) maximum work, ii) change in availability,
	iii) irreversibility. For air, take $C_V = 0.718$ kJ/kg K, $u = C_V \times T$ where C_V is constant, and
	pV=mRT where p is pressure in kPa, V is volume in m ³ , m is mass in kg,
	R = 0.287 kJ/kg K, and T is temperature in K. [5+5]
المستحر بر و	
	4.a) What is sensible heat? How is the sensible heat loss from a human body affected by the
	skin temperature environment temperature, and air motion.
	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of
	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m ³ /min is mixed adiabatically with the outside air at 32°C and 60 percent relative
	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m ³ /min is mixed adiabatically with the outside air at 32°C and 60 percent relative
	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m ³ /min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m ³ /min. assuming that the mixing processes occurs at a pressure
	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m ³ /min is mixed adiabatically with the outside air at 32°C and 60 percent relative
I/Q	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³/min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m³/min. assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture. [5+5] OR
K8	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³/min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m³/min. assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture. OR Staturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³/min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 50 m³/min assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture.
K8	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³/min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m³/min. assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture. [5+5] OR
K8	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³/min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m³/min. assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture. [5+5] Tor the atmospheric air at room temperature of 30°C and relative humidity of 60%. Determine partial pressure of air, humidity ratio, dew point temperature, density and enthalpy of air.
K8	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³/min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m³/min. assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture. Solution Solution
K8	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³ /min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m³ /min. assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture. OR
K8	b) Saturated air leaving the cooling section of an air conditioning system at 14°C at a rate of 50 m³/min is mixed adiabatically with the outside air at 32°C and 60 percent relative humidity, at a rate of 20 m³/min. assuming that the mixing processes occurs at a pressure of 1 atm, determine the specific humidity, the relative humidity, the dry bulb temperature, and the volume flow rate of the mixture. Solution Solution

